

TOWN OF WEST SENECA



ENGINEERING DEPARTMENT

TOWN SUPERVISOR
SHEILA M. MEEGAN
TOWN COUNCIL
EUGENE P. HART
JOHN M. RUSINSKI

July 18, 2012

Honorable Town Board
Town of West Seneca

**Re: 2012 Highway Garage Roofing project
Request to Accept Bid**

Honorable Board Members,

The bid opening for the above referenced project was held on June 21, 2012 at 10:00am. 5 bids were received. We bid this project two different ways. Bid A contained and SBS Modified Roofing Product and Bid B contained a EPDM roofing product. The SBS modified roofing product has a total thickness of 277 mils and is a 2 ply system. The EPDM has a 90 mil thickness and is a 1 ply system. Both products were bid with a 30 year warranty. The low bidder for Bid A (SBS Modified roofing system) was Weaver Metal and Roofing in the amount of \$398,000. The low bidder for Bid B (EPDM Roofing System) was Sahlem's Roofing in the amount of \$384,143.00.

Our opinion is that the quality of the SBS modified system exceeds that of the EPDM system. Given the relatively small cost difference in these systems, it is our opinion that a contract be awarded to Weaver Metal and Roofing in the amount of \$398,000 for this work.

Very truly yours,

A handwritten signature in black ink, appearing to read "S. Tanner", is written over a horizontal line.

Steven R. Tanner, P.E.
Town Engineer

cc: Files: TB.
Project

JUL 23 2012
6.