

Local Law No. 2: Modification to Chapter 75 of the Town Code,
Fire Prevention

Add the following language:

75-6.5 F

Emergency Lighting when required to be located in structures, the Town does not permit the combination of exit/emergency lighting. The intent is to illuminate the exit and exit ways. Exception: Emergency Lighting not required with automatic generator installations.